



TECHNICAL DATA SHEET

PRODUCT NAME:	POLYALUMINIUM CHLORIDE FOR DRINKING WATER TREATMENT (SOLD)	INSPECTION STANDARD :	GB15892-2009
BATCH NO :	20190319	INSEPTION DATE:	20190319
		EXPIRATEION DATE:	20220319
TESTING ITEM		INDEX	RESULT
Apperance		light yellow powder	Complies
Aluminum Oxide AL ₂ O ₃ Content		29	29.5
Basicity %		40-90	73
Water insoluble matter		<0.5	0.2
Nitrogen %		<0.01	Complies
Sulphate %		<0.1	Complies
Fe %		<0.1	Complies
As %		<0.0005	Complies
Cd %		<0.0002	Complies
Cr ⁶⁺ %		<0.0002	Complies
Cr		<0.0003	Complies
Pb %		<0.001	Complies
Mn %		<0.002	Complies
Hg %		<0.00001	Complies